## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING NO. 7165-0085:167

CATEGORY: Control Unit (Non-High Rise)

LISTEE: ADT Security Systems, 4128 North Freeway Blvd., Sacramento, CA 95834

Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942\*

**DESIGN:** System 472407 (Focus 75) control unit. Suitable for local and central

station systems. Refer to listee's data sheet for detailed product description and

operational considerations. System components:

472408 Relay Module 472409 Interface Module

472403 Indicator Module (optional) 472402 Backup Dialer Module (optional) 472401 Remote 8 Point Module (optional)

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes

and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicating

devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for

details.

NOTE: Burglary and other non-fire functions were not examined.

XLF: 7165-0078: 161

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**JUNE 8, 2002** Date Issued: Listing Expires June 30, 2003

**DIANE K. AREND**, Senior Deputy Authorized By:

Program Manager